



# CB TEST CERTIFICATE

Ref. Certificate No.

IT-10651

## IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

Issued by: IMQ SpA


Product: Circuit-breakers for overcurrent protection for household and similar installations

Applicant: LEGRAND SNC 128 AVENUE DE LATTRE France  
DE TASSIGNY  
87045 LIMOGES CEDEX

Manufacturer: BTICINO S.p.A. - VIALE BORRI 231 Italy  
LEGRAND GROUP 21100 VARESE

Factory: BTICINO S.p.A. - VIA DELLE INDUSTRIE 12 Italy  
LEGRAND GROUP 80059 TORRE DEL GRECO (NA)  
nb: Additional factory information on page 2

Rating and principal characteristics: 1P (230/400V); 2P; 3P; 4P (400V); 50/60 Hz; In 0,5 to 63 A; Type B-C-D; Icn 6000A (see Test Reports)

Trade mark (if any): legrand  


Type of Manufacturer's Testing Laboratories used: WMT

Model/Type reference: Series DX<sup>3</sup> (see on pages 7, 8, 9 and 10 of Test Report Ref. No. 03SL00006/00)

Additional information:

Sample of product tested to be in conformity with IEC: 60898-1(ed.1);am1;am2 National differences: EU Group Differences

Test Report Ref. No: 03SL00006/00 - 03SL00006/1 to 03SL00006/59


This CB Test Certificate is issued by the National Certification Body:

IMQ SpA  
Via Quintiliano 43 I-20138 Milano, Italy

Signed by: Mauro Casari

Date of issue: 2011-04-19





**IEC SYSTEM FOR CONFORMITY TESTING  
TO STANDARDS FOR SAFETY OF  
ELECTRICAL EQUIPMENT (IECEE) CB  
SCHEME**

Ref. Certificate No.

IT-10651

**LEGRAND FAEL LTD**  
UL. WARYNSKIEGO 20  
ZABKOWICE SLASKIE  
**Poland**

**BUFER LEGRAND**  
GOSB GEBZE ORGANIZE SANAYI BOLGESI 100  
CADDE N.112  
41480 GEBZE/KOCAELI  
**Turkey**

Additional information (if necessary)

This CB Test Certificate is issued by the National Certification Body:

IMQ SpA  
Via Quintiliano 43 I-20138 Milano, Italy

Signed by: Mauro Casari

Date of issue: 2011-04-19

